

**ADDENDUM NO. 3**  
**April 24, 2020**

City of Pacific  
100 3<sup>rd</sup> Avenue SE  
Pacific, WA 98047

**City of Pacific – Public Works Building**

To: All Holders of Contract Documents

This addendum forms a part of the Contract Documents and modifies the original Specifications and Drawings, bid date ~~May 5 April 28-14~~, 2020.

Acknowledge receipt of this addendum on the Bid Proposal. Failure to do so may subject the bidder to disqualification.

This addendum consists of:

One (1) pages of text (including this cover sheet).

**The following questions were received from contractors.**

1. What is the intent of the site grading? Can grades be adjusted for no net export?

*The intent of the project is to have a graded site that drains to the low points shown. Elevations can be adjusted to achieve no net export of material. Native materials can be left on site in the areas shown as landscaping along northerly and easterly 20 feet wide perimeter. The mounding shall not exceed two feet above existing grade at the center point and slope to existing grade at the edges..*